

Display Energy Certificate

How efficiently is this building being used?



Hamilton Primary School
Hamilton Primary School
9 Priory Road
HIGH WYCOMBE
HP13 6SG

Certificate Reference Number:
0980-8003-0121-8120-2084

This certificate indicates how much energy is being used to operate this building. The operational rating is based on meter readings of all the energy actually used in the building. It is compared to a benchmark that represents performance indicative of all buildings of this type. There is more advice on how to interpret this information on the Government's website www.communities.gov.uk/epbd.

Energy Performance Operational Rating

This tells you how efficiently energy has been used in the building. The numbers do not represent actual units of energy consumed; they represent comparative energy efficiency. 100 would be typical for this kind of building.

More energy efficient

A 0-25

B 26-50

C 51-75

D 76-100

77 100 would be typical

E 101-125


F 126-150

G Over 150

Less energy efficient


Total CO₂ Emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.



Previous Operational Ratings

This tells you how efficiently energy has been used in this building over the last three accounting periods



Technical information

This tells you technical information about how energy is used in this building. Consumption data based on actual meter readings.

Main heating fuel: Natural Gas

Building Environment: Heating and Natural Ventilation

Total useful floor area (m²): 1838

Asset Rating: Not available

	Heating	Electrical
Annual Energy Use (kWh/m ² /year)	146	19
Typical Energy Use (kWh/m ² /year)	146	40
Energy from renewables	0%	0%

Administrative information

This is a Display Energy Certificate as defined in SI 2007/991 as amended

Assessment Software: ORCalc V2-00-02

Property Reference: 882032280000

Assessor Name: Mr Kenneth Butters

Assessor Number: ECMK220047

Accreditation Scheme: ECMK

Employer/Trading Name: Personal Touch Energy Surveyors

Employer/Trading Address: The Adam Suite Nostell Estate Yard Doncaster Road, Nostell York

Issue Date: 17-09-2009

Nominated Date: 30-07-2009

Valid Until: 29-07-2010

Related Party Disclosure: n/a

Recommendations for improving the energy efficiency of the building are contained in the accompanying Advisory Report.